

Don Campbell ULC fire monitoring system reset procedure

The fire reset code for Don Campbell fire monitoring system is

7777

Make sure the fire alarm system has been fully reset and there are no troubles present before attempting to reset the ULC fire monitoring system.

- 1- Enter the main floor IT room, you will see a red enclosure on the right hand side of the room towards the back wall, the **Reset Keypad** is located on the same wall and is located to the right of the red enclosure



Fire reset keypad

- 2- To reset the fire system you must enter the reset code on the keypad (7777) 3 times in a row
- 3- After entering the code 3 times the fire zones on the monitoring system will be reset and any troubles will be cleared